

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF MURRAY #3 WATER)	
DISTRICT FOR A DEVIATION FROM THE)	
REQUIREMENTS OF 807 KAR 5:066,)	CASE NO. 89-366
SECTION 11(2)(a) REGARDING WATER)	
LINE EXTENSION)	

O R D E R

By application received December 4, 1989, Murray #3 Water District ("Murray #3") requested a deviation from 807 KAR 5:066, Section 11(2)(a), which limits the maximum length of small diameter water mains. Murray #3 has requested Commission approval to operate a 2-inch water line in excess of the maximum length allowed by regulations. This is an existing 2-inch water line located in Oakwood Terrace Subdivision. Murray #3 filed information that indicates that adequate service can be provided on this 2-inch extension.

The Commission, having reviewed the evidence of record and being otherwise sufficiently advised, finds that:

1. The existing 2-inch water main is in excess of the length allowed by Commission regulation.

2. Murray #3 should be allowed to operate this 2-inch water main extension as long as adequate and reliable service can be provided in accordance with Commission regulations.

3. If the level of service on this extension or any other main is inadequate or declining, or the pressure is outside the

requirements of 807 KAR 5:066, Section 6(1), Murray #3 should take necessary actions to maintain the level of service in conformance with Commission regulations.

IT IS THEREFORE ORDERED that:

1. Murray #3 be and it hereby is granted a deviation from 807 KAR 5:066, Section 11(2)(a), and is granted permission to operate a 2-inch water line, which exceeds in length the maximum length allowed by Commission regulations. The approval of the operation of this line, which serves the Oakwood Terrace Subdivision, is contingent upon adequate and reliable service being provided in compliance with Commission regulations.

2. Murray #3 shall monitor the adequacy of this line extension. If the level of service on this extension is inadequate or declining, or the pressure is outside the requirements of 807 KAR 5:066, Section 6(1), Murray #3 shall take necessary actions to maintain the level of service in conformance with Commission regulations.

Done at Frankfort, Kentucky, this 29th day of January, 1990.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman

ATTEST:


Executive Director

Commissioner